






FOR USE WITH AWG 12, 14 AND 16



FOR USE WITH CABLE TYPE:
PLTC, PLTC-ER, ITC, ITC-ER, MC, MV AND TC

FOR USE IN CLASS I, DIVISION 2 GROUPS A, B, C AND D
HAZARDOUS LOCATIONS OR UNCLASSIFIED LOCATIONS

THE INSTALLATION MUST BE IN
ACCORDANCE WITH THE
ASSOCIATED LOCATION
RESTRICTIONS OF THE NATIONAL
ELECTRIC CODE OR CANADIAN
ELECTRICAL CODE AS
APPLICABLE, INCLUDING ISSUES
SUCH AS THE ROUTING,
SUPPORT AND LENGTH OF THE
INVOLVED CORD OR CABLE.



		All Dimensions in mm Original Size DIN A3		Scale 1:1	Free size tol.	Ref.		
						Sub.		
		All rights reserved		Created by longl	Inspected by wangst	Standardisation	Date 25-Jun-2025	State 40 - Released
		Department EL PD		Title HAN 10EX UL-AGG-QB				
HARTING D-32339 Espelkamp		Type TB	Design Number DS00199074	SAP Mat. Number 09365101301			Rev. E	Page 1/2



To separate connectors, insert small flat head tool or screwdriver between metal lever and housing as shown in the diagram. Press screwdriver in a downward direction until the metal lever releases.

To secure the hood and housing assembly together, press the metal levers in the upward direction until metal lever latches into housing pins.