





FOR USE WITH AWG 12, 14 AND 16

FOR USE WITH CABLE TYPE:
PLTC, PLTC-ER, ITC, ITC-ER, MC, MV AND TC


FOR USE IN CLASS I, DIVISION 2 GROUPS A, B, C AND D
HAZARDOUS LOCATIONS OR UNCLASSIFIED LOCATIONS



WARNING
EXPLOSION HAZARD
DO NOT CONNECT
OR DISCONNECT
UNDER LOAD!

THE INSTALLATION MUST BE IN ACCORDANCE WITH THE ASSOCIATED LOCATION RESTRICTIONS OF THE NATIONAL ELECTRIC CODE OR CANADIAN ELECTRICAL CODE AS APPLICABLE, INCLUDING ISSUES SUCH AS THE ROUTING, SUPPORT AND LENGTH OF THE INVOLVED CORD OR CABLE.

	All Dimensions in mm Original Size DIN A3		Scale 1:1		Free size tol.		Ref.						
							Sub.						
	All rights reserved		Created by longl		Inspected by wangst		Standardisation		Date 25-Jun-2025		State 40 - Released		
	Department EL PD												
HARTING D-32339 Espelkamp			Title HAN 6EX UL-HTE-M20									Doc-Key / ECM-Nr. DS00199065	
			Type TB		Design Number DS00199065				SAP Mat. Number 19365061440			Rev. D	Page 1/2



To separate connectors, insert small flat head tool or screwdriver between metal lever and housing as shown in the diagram,. Press screwdriver in a downward direction until the metal lever releases.

To secure the hood and housing assembly together, press the metal levers in the upward direction until metal lever latches into housing pins.