





FOR USE WITH AWG 12, 14 AND 16

FOR USE WITH CABLE TYPE:
PLTC, PLTC-ER, ITC, ITC-ER, MC, MV AND TC



FOR USE IN CLASS 1, DIVISION 2, GROUP A,B,C, AND D
HAZARDOUS LOCATIONS OR UNCLASSIFIED LOCATIONS



WARNING
EXPLOSION HAZARD
DO NOT CONNECT
OR DISCONNECT
UNDER LOAD!

THE INSTALLATION MUST BE IN
ACCORDANCE WITH THE ASSOCIATED LOCATION
RESTRICTIONS OF THE NATIONAL ELECTRIC CODE
OR CANADIAN ELECTRICAL CODE AS APPLICABLE,
INCLUDING ISSUES SUCH AS ROUTING, SUPPORT
AND LENGTH OF THE INVOLVED CODE OR CABLE.

	All Dimensions in mm Original Size DIN A3		Scale 1:1		Free size tol.		Ref.	
							Sub.	
	All rights reserved		Created by longl		Inspected by wangst		Standardisation	
	Department EL PD						Date 25-Jun-2025	
HARTING D-32339 Espelkamp			Title Han 16Ex UL-HSE-M25				State 40 - Released	
			Type TB		Design Number DS00199110		SAP Mat. Number 19365161521	
						Rev. D		Page 1/2
								Doc-Key / ECM-Nr. DS00199110



To separate connector, insert small flat head tool or screwdriver between metal lever and housing as shown in the diagram, press the screwdriver in a downward direction until the metal lever releases.

To secure the hood and housing assembly together, press the metal lever upward direction until metal lever latches into housing pins.